



CHENNAI METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD

No.1. Pumping Station Road,
Chintadripet, Chennai-02.

Date: 17.03.2025

DETAILS OF WATER SAMPLES TESTED AND THE COMPARATIVE STATEMENT OF TEST ANALYSIS REPORT OF TWO LABORATORIES ON VARIOUS DATES											
SI.NO	Parameter	Unit	Guaranteed Value of TTRO Water at TWST Sump at Koyambedu	Drinking water standards as per IS 10500-2012	Treated Water Storage Sump of TTRO Plant at Koyambedu		Water Sample at				
					Quality Assurance Wing of CMWSSB	Monarch Biotech Pvt.Ltd., Chennai-124	Irungattukottai	Pillaiappakkam	Sriperumbudur	Vallam Vadagal	Oragadam
							Quality Assurance Wing of CMWSSB				
							DATE OF WATER SAMPLING	DATE OF WATER SAMPLING	DATE OF WATER SAMPLING		
		05.02.2025	05.02.2025	05.02.2025	05.02.2025	05.02.2025	05.02.2025	05.02.2025	05.02.2025		
1	pH	-	-	6.5 - 8.5	6.67	6.60	6.81	6.80	6.76	6.82	6.78
2	TDS	mg/l	<70	<500	43	51	45	44	44	43	43
3	COD	mg/l	BDL	BDL	BDL	BLQ	BDL	BDL	BDL	BDL	BDL
4	BOD	mg/l	BDL	BDL	BDL	BLQ	BDL	BDL	BDL	BDL	BDL
5	Total Silica	mg/l	<5	<5	0.45	0.64	0.61	0.52	0.58	0.60	0.57
6	Total Coliform Bacteria	per 100ml	Absent/ 100 ml	Absent/ 100 ml	Absent	-	Absent	Absent	Absent	Absent	Absent
7	Escherichia Coli	per 100ml	Absent/ 100 ml	Absent/ 100 ml	-	-	-	-	-	-	-
REMARKS				THE ABOVE TEST SAMPLES ARE WITH IN THE ACCEPTABLE LIMIT OF DRINKING WATER STANDARDS AS PER IS 10500-2012							